

INTERSTITIAL MONITORING LOG FOR DOUBLE WALLED TANKS

Tank ID#

Facility Name

racinty Name	1 dik 1D#			
Facility Address				
Product	Tank Size			
	RESULTS OF	WEEKLY VISUAL	INSPECTION	
Date Weekly Leak	Space Dry?	Water Observed?	Product Observed?	Inspector's
Check Performed	Yes/No	Yes/No	Yes/No	Initials

Instructions: Use a clean stick, not one that has been used previously in an oil tank. At the very bottom of the stick, dab a small amount of gas paste on one side and a small amount of water paste on the other side. Lower the stick to the bottom of the interstitial space and raise it back up. If either the gas paste or water paste has turned color, clean the stick and repeat the procedure. If either the gas paste or water paste has again turned color, a tank leak is indicated.

Contact the NYSDEC Spill Response Hotline at 1-800-457-7362 as soon as possible and within 24 hours. If the paste has not changed color, simply fill in the date in the left hand column, enter the 'No' in the water and product columns, and put your initials in the right hand column. Check weekly!

KEEP THIS COMPLETED FORM ON SITE FOR THREE YEARS